



TRANSPORTATION & CIVIC WORKS DEPARTMENT

Water Analysis Test Results for Millennium Ponds August 24, 2020

The City of Castlegar has analyzed the water from all 3 ponds with these results:

POND #1	POND #2	POND #3
Less than 1 CFU/100mL	2 CFU/100mL	Less than 1 CFU/100mL

400 CFU/100ML is the individual test limit set by Interior Health.